

Certificate of Compliance

Certificate: 1290683 (LR 112560)

Master Contract: 189340

Project: 1290683

Date Issued: June 4, 2002

Issued to: **NORD MOTORIDUTTORI s.r.l.**
Via Modena, 14
I-40019 Sant'Agata Bolognese (BO)
ITALY

The products listed below are eligible to bear the CSA Mark shown



Issued by:  J-P. Boivin, Eng.

Authorized by: Alain Ste-Marie
Operations Manager

PRODUCTS

CLASS 4228 01 -- MOTORS AND GENERATORS - For Hazardous Locations

Class I, Division 2, Groups C and D
Class II, Divisions 2, Groups F and G
Temperature Code T3C-165C

Squirrel-cage induction motors, Three-phase, Four pole, Insulation Class F-155, 230/460v a.c., 60Hz, Ambient Rated 40C, continuous duty, TEFC, Service Factor 1.15.

MODEL	OUTPUT (kW)	RATED CURRENT, (A at 230/460 & 332/575v)	RPM
63S/4	0.12	0.88/0.44-0.64/0.37	1700-1710
63L/4	0.18	1.12/0.56-0.80/0.46	1680-1690
71S/4	0.25	1.56/0.78-1.14/0.66	1710-1720
71L/4	0.37	1.90/0.95-1.38/0.80	1720-1730
80S/4	0.55	2.70/1.35-1.94/1.12	1710-1715
80LH/4	0.75	3.88/1.94-2.6/1.5	1750-1750

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

